

ADDENDUM TO THE FACT SHEET
FOR NATIONAL POLLUTANT DISCHARGE
ELIMINATION SYSTEM (NPDES)
PERMIT NO. WA-002318-3

AUGUST 4, 2010

I. GENERAL INFORMATION

Facility:

CITY OF CASHMERE
PUBLICLY-OWNED TREATMENT WORKS
101 WOODRING STREET
CASHMERE, WA 98815

II. APPLICATION REVIEW

The City of Cashmere (Cashmere) submitted an application to Ecology on November 19, 2009 for permit reissuance, and Ecology accepted it on November 30, 2009. Ecology has sufficiently reviewed the application, discharge monitoring reports, and other facility information in enough detail to ensure that:

- Cashmere has substantially complied with all of the terms, conditions, requirements and schedules of compliance of the expired permit.
- Ecology has up-to-date information on the Cashmere waste treatment practices, the facility's production levels; and the nature, content, volume, and frequency of its discharge.
- The discharge meets applicable effluent standards and limits, water quality standards, and other legally applicable requirements.

III. PERMIT REAUTHORIZATION

When Ecology reauthorizes a discharge permit it essentially reissues the permit with the existing limits, terms and conditions. Alternatively, when Ecology renews a permit it re-evaluates the impact of the discharge on the receiving water, which may lead to changes in the limits, terms and conditions of the permit.

This fact sheet addendum accompanies the permit, which Ecology proposes to reauthorize for the discharge of wastewater to the Wenatchee River. The previous fact sheet explains the basis for the discharge limitations and conditions of the reauthorized permit and remains as part of the administrative record.

Ecology determined it does not need to substantially change the existing permit requirements, including discharge limits and monitoring, to protect the receiving water

quality with the exception or revising the compliance schedule as noted below. The existing permit includes a compliance schedule for Cashmere to meet the requirements of the (TMDL) implementation plan. Since the issuance of the current permit, Ecology completed the Wenatchee River Watershed pH and Dissolved Oxygen Wenatchee River total maximum daily load (TMDL) study. The reauthorized permit requires the Permittee to upgrade its plant to meet the requirements of the Wenatchee River TMDL. The Cashmere POTW currently meets the requirements of the Wenatchee River Temperature TMDL. The reauthorized permit is virtually identical to the previous permit issued on October 28, 2005, with the exception of the revised compliance schedule.

Ecology has removed sulfite monitoring from the proposed permit because it now has sufficient data for analysis. The previous fact sheet addressed conditions and issues at the facility at the time when Ecology issued the previous permit in October 2005.

Ecology reviewed inspections and assessed compliance of the Cashmere facility's discharge with the terms and conditions in the previous permit and determined that it should not rank the facility as a high priority for permit renewal. Ecology assigns a high priority for permit renewals in situations where water quality would benefit from a more stringent permit during the next five-year cycle.

The permit reauthorization process, along with the renewal of high priority permits, allows Ecology to reissue permits in a timely manner and minimize the number of active permits that have passed their expiration dates. For permit reissuance planning purposes, Ecology follows a system of ranking that considers the benefit gained by renewing a permit rather than reauthorizing a permit during its annual permit planning process. Ecology assesses each permit that is expiring and due for reissuance and compares it with other permits due for reissuance. Ecology notifies the public and seeks input after it has tentatively established the initial draft ranking of the permits it plans to renew and those it plans to reauthorize. Ecology considers all relevant comments and suggestions before it makes a final decision.

As required by the existing permit, Cashmere submitted a General Sewer Plan and Wastewater Facility Plan prepared by RH2 Engineering, Inc. Ecology accepted the plan on November 25, 2009. The plan outlines alternatives for a proposed major upgrade of the facility. The upgrade is needed to address the present leaking lagoon system and achieve compliance with the Wenatchee River dissolved oxygen and pH total maximum daily load (TMDL) by 2019. The plan provides a timeline for submittal of an approvable engineering report and construction of the upgraded plant. The permit requires Cashmere to adhere to the timeline presented in the plan.

*ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015
Page 3 of 10*

Tree Top Inc., Cashmere's largest industrial user, suspended operation at the Cashmere plant approximately three years ago and at this time it is uncertain if the plant will become active in the proposed permit cycle. For this reason, Ecology carried over the discharge limits and conditions in effect at the time of expiration of the previous permit to this reauthorized permit. Ecology will require monitoring of the industrial discharge only in the event the plant becomes active once more.

Ecology only changed the submittal dates for reports from those in the previous permit. Ecology removed the completed report requirements that do not require additional or continued assessment. It adjusted the dates for the other standard compliance and submittal requirements that it carried over from the past permit into this reauthorized permit. Ecology considered these reports necessary in the previous permit and no information has come forward to cause it to reconsider.

Ecology must public notice the availability of the draft reauthorized permit at least 30 days before it reissues the permit [Washington Administrative Code (WAC) 173-220-050]. Ecology invites you to review and comment on its decision to reauthorize the permit (see Appendix A-Public Involvement for more detail on the Public Notice procedures).

After the public comment period has closed, Ecology will prepare a response to comments document that it will attach to this fact sheet addendum. The response to comments will include the resultant changes to the permit and either addresses each comment individually or summarizes the substantive comments and respond. Ecology sends a copy of the response to comments to all parties who submitted comments. Ecology will include the response to comments in this fact sheet addendum.

IV. RECOMMENDATION FOR PERMIT ISSUANCE

Ecology proposes to reissue this permit for 5 years.

APPENDIX A--PUBLIC INVOLVEMENT INFORMATION

Ecology proposes to reauthorize a permit to the City of Cashmere. The permit includes wastewater discharge limits and other conditions. This fact sheet addendum describes the facility and Ecology's reasons for reauthorizing the permit conditions.

Ecology will place a Public Notice of Draft Reauthorization on September 3, 2010 in the Wenatchee World to inform the public and to invite comment on the proposed draft National Pollutant Discharge Elimination System permit and fact sheet addendum.

The Notice –

- Tells where copies of the draft Permit and Fact Sheet are available for public evaluation (a local public library, the closest Regional or Field Office, posted on our website.).
- Offers to provide the documents in an alternate format to accommodate special needs.
- Urges people to submit their comments, in writing, before the end of the Comment Period
- Tells how to request a public hearing of comments about the proposed NPDES Permit.
- Explains the next step(s) in the permitting process.

**NOTICE: ANNOUNCEMENT OF AVAILABILITY OF DRAFT
REAUTHORIZATION PERMIT**

PERMIT NO.: WA-002318-3

**APPLICANT: CITY OF CASHMERE
101 WOODRING STREET
CASHMERE, WA 98815**

has applied for renewal of National Pollutant Discharge Elimination System (NPDES) Permit No. WA-002318-3 in accordance with the provisions of Chapter 90.48 Revised Code of Washington (RCW), Chapter 173-220 Washington Administrative Code (WAC), and the Federal Clean Water Act.

Following evaluation of the application and other available information, a draft reauthorization permit has been developed which would allow the discharge of municipal wastewater to a maximum of 943,000 gallons per day to the Wenatchee River at River Mile 8.6 from its facility located at Riverfront Drive, Cashmere, WA. All discharges to be in compliance with the Department of Ecology's Water Quality Standards for a permit to be issued.

A tentative determination has been made to reauthorize this permit based on the effluent limitations and special permit conditions that will prevent and control pollution. A final determination will not be made until all timely comments received in response to this notice have been evaluated.

*ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015
Page 5 of 10*

PUBLIC COMMENT AND INFORMATION

The draft permit and fact sheet may be viewed at the Department of Ecology (Department) website: http://www.ecy.wa.gov/programs/wq/permits/central_permits.html. The application, fact sheet, proposed permit, and other related documents are also available at the Department's Central Regional Office for inspection and copying between the hours of 8:00 a.m. and 5:00 p.m., weekdays. To obtain a copy or to arrange to view copies at the Central Regional Office, please call Cindy Huwe at 509/457-7105, e-mail cynthia.huwe@ecy.wa.gov, or write to the address below.

Interested persons are invited to submit written comments regarding the proposed permit. All comments must be submitted by October 3, 2010 (within 30 days of the final date of publication of this notice) to be considered for the final determination. Comments should be sent to: Department of Ecology, Central Regional Office, 15 West Yakima Avenue, Suite 200, Yakima, WA 98902, Attention: Cindy Huwe. E-mail comments should be sent to Cindy Huwe at cynthia.huwe@ecy.wa.gov.

Any interested party may request a public hearing on the proposed permit within 30 days of the publication date of this notice. The request for a hearing shall state the interest of the party and the reasons why a hearing is necessary. The request should be sent to the above address. The Department will hold a hearing if it determines that there is significant public interest. If a hearing is to be held, public notice will be published at least 30 days in advance of the hearing date. Any party responding to this notice with comments will be mailed a copy of a hearing public notice. Please bring this public notice to the attention of persons who you know would be interested in this matter. The Department is an equal opportunity agency. If you have a special accommodation needs, please contact Cindy Huwe at 509/457-7105 or TTY (for the speech and hearing impaired) at 1-800-833-6388.

Publication date of this Notice is September 3, 2010.

Ecology has published a document entitled **Frequently Asked Questions about Effective Public Commenting** which is available on our website at <http://www.ecy.wa.gov/biblio/0307023.html>.

You may obtain further information from Ecology by telephone 509-457-7105 or by writing to the permit writer at the address listed below.

Water Quality Permit Coordinator
Department of Ecology
Central Regional Office
15 West Yakima Avenue, Suite 200
Yakima, WA 98902

The primary author of this permit and fact sheet is Richard Marcley.

**ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015**

Page 6 of 10

APPENDIX B--DISCHARGE MONITORING DATA

WA0023183														
Surface Water Body		CASHMERE POTW		Dept of Ecology										
2		shaded cell indicates either a compliance violation or questionable data entry that is not verifiable												
Ammonia (Total)			Biochemical Oxygen Demand (BOD5) (Not Applicable)					Chlorine residual		D.O.	Flow			
Lbs/Day		Mg/L	Lbs/Day		Mg/L		Percent	Lbs/Day	Mg/L	Mg/L	MGD			
Max		Min	Ave Mon	Week Ave	Week Ave	Ave Mon	Minimum	Daily Max	Daily Max	Average	Max			
Date	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value			
1/2/2007	41.84	9.71	137	203	56	35	90	0.21	0.05	5.4	0.6276			
2/5/2007	36.46	9.79	188	239	64	47	88	0.21	0.05	5.9	0.6196			
3/5/2007	52.67	11.5	61	138	30	14	96	0.23	0.05	8.6	103			
4/1/2007	29.87	8.36	54	64	18	15	93	0.17	0.04	6.4	0.524			
5/3/2007	40	10.9	44	55	16	14	96	0.15	0.05	5.1	0.4963			
6/6/2007	21.83	7.54	66	87	28	23	86	0.17	0.05	5.5	0.6324			
7/1/2007	19.97	10.4	21	31	28	23	94	0.09	0.05	4.9	0.3404			
8/4/2007	25.36	11	30	61	26	16	96	0.19	0.05	4.4	0.4508			
9/7/2007	35.21	11.6	51	77	22	19	95	0.19	0.05	23	0.4324			
10/2/2007	43.43	12	59	71	20	18	93	0.18	0.05	6.5	0.4412			
11/5/2007	39.16	10.6	83	110	31	21	93	0.23	0.05	7.5	0.6148			
12/7/2007	2	2	95	129	34	30	84	0.25	0.05	4	0.5977			
1/3/2008	20.43	13.1	50	69	44	37	87	0.06	0.05	6.2	0.2136			
2/6/2008	35.87	13.2	134	195	83	65	91	0.14	0.05	5.2	0.3308			
3/7/2008	42.66	13.9	153	242	60	51	80	0.29	0.05	4.7	0.692			
4/3/2008	45.04	15.1	65	93	41	29	96	0.05	0.04	11	0.628			
5/5/2008			23	51	46	30	97	0.09	0.05	18	0.256			
6/1/2008	15.67	9.35	24	63	37	26	99	0.08	0.05	21	0.214			
7/3/2008	7.93	9.08	35	81	39	21	91	0.22	0.05	4.6	0.5636			
8/6/2008	4.08	4.8	24	39	44	24	97	0.06	0.05	4.3	0.1364			
9/2/2008	15.81	4.59	22	35	26	17	98	0.29	0.05	5.7	0.6892			
10/4/2008	8.34	5.88	21	31	20	15	99	0.1	0.05	4.5	0.2344			
11/7/2008	35.87	9.12	89	162	34	21	95	0.21	0.05	5.6	0.8826			
12/2/2008	23.87	14.6	48	84	45	31	97	0.12	0.05	6	0.3084			
1/5/2009	38.81	14.8	130	192	54	50	87	0.22	0.05	5.7	0.532			
2/1/2009	28.22	14.3	117	236	41	40	86	0.31	0.05	4.9	0.7444			
3/1/2009	35.31	13	68	121	36	31	93	0.19	0.05	5.4	0.4476			
4/4/2009	19.95	13.9	33	42	29	22	97	0	0	3.5	0.206			
5/6/2009	22.92	13.5	30	38	21	18	96			3	0.6064			
6/2/2009	6.12	3.95	50	58	17	16	96	0	0	3.5	0.9508			
7/4/2009	2.4	1.97	16	22	20	15	99	0	0	3.2	0.2004			
8/7/2009	2.91	3.73	5	8	10	7	99	0	0	5	0.1024			
9/3/2009	8.2	4.1	32	90	16	11	98			3.2	0.936			
10/5/2009	9.19	6.66	34	55	27	21	98	0.09	0.02	3.7	0.4816			
11/1/2009	10.95	4.06	91	146	24	21	94	0.13	0.05	2.9	0.7956			
12/3/2009	38.19	11.2	74	89	29	24	95	0	0	8	0.4781			
1/6/2010	67.74	16	89	95	28	23	94	0.22	0.04	3.7	0.5668			
2/2/2010	68.73	17.4	78	98	21	26	95	0.21	0.05	9.2	0.52			
3/2/2010	73.7	17.6	72	99	23	20	95	0.18	0.01	3.9	0.528			
4/5/2010	58.83	17	88	105	30	23	91	91	0.24	0.05	2.9			
Min	2	1.97	5	8	10	7	80	0	0	2.9	0.1			
Max	73.7	17.6	188	242	83	65	99	0.31	0.05	23	103			
Avg	29.12	10.29	64.6	97.6	32.95	25.25	93.54	0.15	0.04	6.39	3.07			
Median	28.22	10.9	56.5	85.5	29	22.5	95	0.18	0.05	5.15	0.53			
95th %	68.73	17.4	137	236	60	50	99	0.29	0.05	18	0.94			

**ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015**

Page 7 of 10

	Kjeldahl Nitrogen (TKN) (Total)				Phosphorus (Total)				Solids (Residue) (Total suspended (TSS))				
	Lbs/Day		Mg/L		Lbs/Day		Mg/L		Lbs/Day		Mg/L		Percent
	Min	Max	Min	Max	Max	Max	Max	Max	Week Ave	Ave Mon	Week Ave	Ave Mon	Minimum
Date	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value
1/2/2007		69.5	17.8		14.81			3.4	271	208	56	52	71
2/5/2007		74.38	20.8		47.74			10.6	338	267	85	66	36
3/5/2007		68	15.2		10.31			2.25	211	118	46	26	78
4/1/2007		41.03	12		11.29			3.24	345	145	100	41	52
5/3/2007		58.35	15.9		33.25			9.06	102	83	30	27	90
6/6/2007		25.66	10.04		13.08			4.39	234	131	70	44	79
7/1/2007	31.49			39.5	12.29	12.29	5.77	5.77	41	30	37	32	96
8/4/2007	36.64			14.7	14.48	14.48	5.71	5.71	129	75	60	44	87
9/7/2007	49.18			16.2	21.13			6.96	141	111	50	41	88
10/2/2007									143	94	40	28	89
11/5/2007		65.12	16.5		21.63			5.94	220	175	54	45	64
12/7/2007		73.22	15.7		15.86			3.43	252	185	66	56	66
1/3/2008		16.64	15.4		3.59			3.3	68	47	38	35	87
2/6/2008		62.07	22.5		10.76			3.97	106	86	46	38	88
3/7/2008		61.08	19.9		12.18			3.97	208	121	42	40	74
4/3/2008		52.87	21.8		9.73			4.15	131	59	37	24	92
5/5/2008									58	26	29	24	91
6/1/2008		22.12	13.9		9.76			7.1	31	15	21	18	98
7/3/2008	19.4			13.8	8.46	8.46	6.55	6.55	103	41	51	27	92
8/6/2008	5.44			6.4	2.62	2.62	2.94	2.94	101	45	114	48	92
9/2/2008	34.49			7.2	18.57	18.57	3.55	3.55	90	35	28	18	95
10/4/2008		11.06	7.8		6.71			4.41	43	28	28	19	93
11/7/2008		51.92	13.2		16.99			4.32	192	113	42	28	82
12/2/2008		37.87	21.1		9.01			5.45	105	56	47	34	86
1/5/2009		58.47	22.3		10.72			4.24	228	161	70	62	68
2/1/2009		42.86	21.1		8.91			4.36	211	120	52	44	75
3/1/2009		52.96	18.9		11.1			3.96	128	68	36	30	61
4/4/2009		25.02	18		5.66			3.84	33	28	20	19	96
5/6/2009		26.49	15.6		6.8			4.01	105	54	62	31	86
6/2/2009		28.8	9.5		12.49			3.81	103	101	36	33	80
7/4/2009	6.69			5.3		3.52	2.92		26	15	23	16	97
8/7/2009	4.76			6.1		2.82	3.63		17	9	21	12	96
9/3/2009	47.29			7.6		28.03	5.02		206	86	45	29	59
10/5/2009		9.91	6.6		15.54			7.2	74	49	35	30	73
11/1/2009		26.13	7.5		19.79			6	153	124	36	30	73
12/3/2009		59.01	17.2		19.42			5.19	135	106	42	34	66
1/6/2010		90.31	31.7		18.12			5.28	122	113	30	29	86
2/2/2010		84.18	21.4		15.58			4.11	133	103	34	27	79
3/2/2010		91.81	23.7		16.16			4.56	118	97	34	27	85
4/5/2010	0.614		80.51	21.8		13.31			3.62	164	111	39	29
Min	4.76	9.91	6.6	5.3	2.62	2.62	2.92	2.25	17	9	20	12	36
Max	49.18	91.81	31.7	39.5	47.74	28.03	6.55	10.6	345	267	114	66	98
Avg	26.15	50.6	17.06	12.98	14.22	11.35	4.51	4.88	140.48	90.98	45.8	33.43	80.18
Median	31.49	52.96	17.2	7.6	12.49	10.38	4.33	4.32	128.5	90	41	30	85.5
95th %	49.18	90.31	23.7	39.5	33.25	28.03	6.55	9.06	271	185	85	56	96

ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015
Page 8 of 10

	Sulfite (Total)		Temp	Coliform, Fecal		pH	pH
	Lbs/Day	Mg/L	Degrees C	#/100ml		S.U.	S.U.
	Maximum	Maximum	Maximum	Ave Mon	Week Ave	Minimum	Maximum
Date	Value	Value	Value	Value	Value	Value	Value
1/2/2007	2	2	3	271	350	6.9	7.5
2/5/2007	2	2	4	396	462	7.1	7.3
3/5/2007	2	2	11	3	6	7.5	8.3
4/1/2007	2	2	13	8	19	8	8.8
5/3/2007	2	2	15	36	95	8.2	8.8
6/6/2007	2	2	17	47	80	8.3	8.9
7/1/2007	2	2	23	59	80	8.1	8.8
8/4/2007	2	2	24	60	98	8	8.7
9/7/2007	2	2	21	83	133	7.9	8.3
10/2/2007	2	2	19	83	94	7.4	8.4
11/5/2007	2	2	10	68	133	7.6	8.3
12/7/2007	38.4	8.2	2	83	192	7.5	7.9
1/3/2008	2	2	3	63	143	7.3	7.8
2/6/2008	2	2	2	135	160	7	7.6
3/7/2008	2	2	6	112	190	7.2	7.6
4/3/2008	2	2	7	25	57	7.4	8.2
5/5/2008			14	131	190	7.5	8.2
6/1/2008	2	2	20	18	75	7.4	8.2
7/3/2008	2	2	22	40	90	7.2	8.8
8/6/2008	2	2	23	18	40	7.4	8.5
9/2/2008	2	2	20	32	135	7.7	8.6
10/4/2008	2	2	18	85	170	4.8	8.2
11/7/2008	2	2	15	64	135	7.3	8.1
12/2/2008	2	2	11	19	90	6.8	7.5
1/5/2009	10.72	4.24	7	29	60	7	7.5
2/1/2009	2	2	7	32	55	7	7.5
3/1/2009	2	2	7	29	82	7	7.4
4/4/2009	2	2	12	18	28	7.1	7.9
5/6/2009	4.2	2.5	15	37	55	7.4	8
6/2/2009	4.2	2.5	16	50	105	7.3	8.6
7/4/2009	2	2	23	30	42	7.6	8.4
8/7/2009	1.8	2.5	24	16	28	7.3	7.8
9/3/2009	2	2	24	34	56	7.3	7.8
10/5/2009	2	2.5	19	78	129	7.1	7.8
11/1/2009	7	3	11	20	27	7.2	7.7
12/3/2009	2	2	4	24	45	6.9	7.8
1/6/2010	2	2	8	54	90	7.3	7.6
2/2/2010	2	2	9	37	61	6.9	7.5
3/2/2010	2	2	10	10	14	7.2	7.5
4/5/2010	61	7	2	13	22	400	7.3
Min	1.8	2	2	3	6	4.8	7.3
Max	38.4	8.2	24	396	462	8.3	8.9
Avg	3.52	2.29	13.3	61.48	112.35	7.31	8.05
Median	2	2	13	37	90	7.3	7.95
95th %	10.72	4.24	24	135	350	8.1	8.8

**ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015
Page 9 of 10**

INFLUENT MONITORING DATA

	INFLUENT												
	Biochemical Oxygen Demand (BOD5) (Not App)				Flow (Not Applicable)			Solids (Residue) (Total suspended (TSS))				pH	pH
	Lbs/Day		Mg/L		MGD			Lbs/Day		Mg/L		Standard U	Standard U
	Maximum	Average	Maximum	Average	Average	Total	Maximum	Maximum	Average	Maximum	Average	Minimum	Maximum
Date	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value
1/2/2007	2776	1823	767	561	0.3796	11.7678	0.5744	1367	894	375	274	7.4	8.4
2/5/2007	1763	1572	600	512	0.3812	10.6738	0.5573	1384	791	436	251	7.3	9.1
3/5/2007	2336	1528	680	465	0.3724	11.5433	0.423	962	823	318	254	7.6	9.1
4/1/2007	1217	1022	420	358	0.3177	9.532	0.3898	2019	872	708	304	7.4	7.9
5/3/2007	1935	1216	513	365	0.4209	13.0465	0.8328	1517	917	443	276	7.4	7.8
6/6/2007	2794	1492	520	377	0.4342	13.0262	0.7444	2111	1188	378	308	7.5	7.7
7/1/2007	1202	645	531	335	0.2693	8.3477	0.337	828	519	430	304	7.3	7.7
8/4/2007	847	640	377	285	0.2693	8.3483	0.2693	993	544	442	242	7.4	7.7
9/7/2007	1071	966	383	345	0.347	10.41	0.371	914	784	318	280	7.3	7.6
10/2/2007	1317	973	480	319	0.3624	11.233	0.56	1289	856	340	250	7.1	7.8
11/5/2007	2228	1309	730	439	0.3501	10.503	0.502	1170	628	370	210	7.5	7.9
12/7/2007	1663	1253	545	429	0.3781	11.722	1.02	998	716	380	249	7.5	7.8
1/3/2008	1877	1157	640	398	0.3305	10.2448	0.377	658	539	234	187	6.4	7.8
2/6/2008	1954	1498	610	464	0.4022	11.664	0.604	1185	840	370	254	7.4	7.7
3/7/2008	2049	1270	740	431	0.3626	11.24	0.467	958	769	346	258	7.4	7.7
4/3/2008	2505	1569	770	526	0.3371	10.113	0.445	1789	1065	550	352	7.3	7.8
5/5/2008	2780	2048	110	716	0.3512	10.887	0.442	1371	686	372	227	7.2	7.9
6/1/2008	2606	1683	930	545	0.3541	10.6239	0.449	1216	880	434	283	7.3	7.9
7/3/2008	1770	1132	550	384	0.333	10.323	0.417	1462	807	520	274	7.3	7.8
8/6/2008	2249	1766	670	653	0.3274	10.149	0.401	1213	697	480	261	7.3	7.9
9/2/2008	1830	1542	630	485	0.3608	10.8236	0.422	1830	757	520	229	7.6	8.1
10/4/2008	2136	1521	660	499	0.3729	11.561	0.538	677	484	232	158	7.2	7.8
11/7/2008	4096	2306	1070	540	0.4141	12.423	0.949	760	592	198	149	7.3	8
12/2/2008	2004	1506	610	489	0.3519	10.91	0.413	592	427	182	137	7	7.8
1/5/2009	2365	1432	475	327	0.4197	13.0121	1.121	1234	679	160	148	5.7	8.2
2/1/2009	1738	1379	550	455	0.3641	10.195	0.463	834	572	264	188	7.3	8.6
3/1/2009	1706	1581	600	528	0.3625	11.237	0.646	721	533	242	177	7.1	7.8
4/4/2009	2338	1522	730	527	0.3575	10.725	0.423	757	687	268	240	7.3	7.9
5/6/2009	1196	1016	610	425	0.3547	10.996	0.704	905	532	328	218	7.3	8
6/2/2009	2728	1586	870	508	0.3667	10.9996	0.435	1336	1045	426	333	7	7.8
7/4/2009	1635	1174	555	413	0.3355	10.399	0.44	1306	558	488	201	7	7.7
8/7/2009	1455	1181	510	392	0.3441	10.666	0.437	764	522	268	171	7	7.8
9/3/2009	1340	1222	425	374	0.3666	11.597	0.466	1475	765	486	243	7.1	7.8
10/5/2009	2634	1649	658	490	0.3922	12.157	0.576	912	580	284	177	7.3	7.9
11/1/2009	1825	1469	585	494	0.3608	10.8923	0.531	1360	739	436	246	7.3	8
12/3/2009	1861	1477	595	480	0.3528	10.936	0.427	976	476	380	164	7.4	7.9
1/6/2010	1535	1283	500	379	0.3773	11.695	0.54	687	539	224	161	7.1	7.8
2/2/2010	2502	1669	750	539	0.3747	10.492	0.741	734	513	220	169	6.3	7.8
3/2/2010	1942	1489	710	518	0.3319	10.289	0.423	1029	716	376	248	5.4	8
4/5/2010	2404	1494	710	510	0.3476	10.4273	0.498	1084	743	380	257	7.1	8.4
Min	847	640	110	285	0.27	8.35	0.27	592	427	160	137	5.4	7.6
Max	4096	2306	1070	716	0.43	13.05	1.12	2111	1188	708	352	7.6	9.1
Avg	2005.23	1401.5	609.23	456.98	0.36	10.95	0.53	1134.43	706.85	365.15	232.8	7.15	7.95
Median	1938.5	1483	605	464.5	0.36	10.89	0.46	1056.5	706.5	373.5	244.5	7.3	7.8
95th %	2780	1823	870	561	0.42	13.01	0.95	1830	1045	520	308	7.5	8.6

*ADDENDUM TO THE FACT SHEET FOR
NPDES PERMIT NO. WA-002318-3
CITY OF CASHMERE POTW
EXPIRATION DATE: NOVEMBER 30, 2015
Page 10 of 10*

APPENDIX C--RESPONSE TO COMMENTS

No comments were received by the Department of Ecology.